

# Memorandum

March 14, 2024

TO: Historical Memo

FROM: Carol Nelson, Process Analyst  
Samayyah Williams, Process Engineer

SUBJECT: Brightwater Treatment Plant  
February 2024 Operating Record

---

All discharge permit requirements were met in February at the Brightwater Treatment Plant (BWTP). All wastewater received Membrane Bioreactor (MBR) secondary treatment. Effluent BOD and TSS averaged <1.0-mg/L and <2.0-mg/L, respectively, and removals were both  $\geq 99\%$ . All fecal coliform results were less than 1-cfu/100-mL. Effluent pH was maintained between 7.0 and 7.7. Continuous dosing of 59% Magnesium Hydroxide [Mg(OH)<sub>2</sub>] was required to ensure permit compliance for pH. Sodium Hydroxide [NaOH] flows of less than 165 gpd added alkalinity on eleven days to insure that the NaOH dosing pumps were available in the event of a low inventory of Mg(OH)<sub>2</sub>.

Effluent flow to Puget Sound averaged 21.4-MGD. Approximately 0.1-MGD of effluent was used for plant processes; influent flow averaged 21.5-MGD. The maximum influent and effluent flows, 25.9-MGD and 25.8-MGD, respectively, occurred after a wet weather event on Jan. 28-31. Influent flows were directed to South Plant via the York Diversion Gate at Hollywood Pump Station on three days in February; the York diversion gate at Hollywood Pump Station was opened for several hours on both Feb. 14 & 28 by Offsite Operations. On Feb. 29 flow was again diverted while setpoints for the York Diversion gate were adjusted so it will work as designed to shed flow automatically when upstream sewer levels are high. Repairs to telemetry between Hollywood and Brightwater, noted last month, are ongoing. The monthly total influent sewage directed to South Plant was approximately 0.8-MG. Membrane capacity ranged between 41-MGD and 46-MGD.

February rainfall totaled 3.6-inches based on local rain gauges. The wettest period occurred on Feb. 27-29 (1.5-inches). Precipitation recorded for SeaTac Airport was 3.8-inches of rain, which is within 0.1-inches of normal. Local area air temperatures averaged 44.3°F, which is 0.3°F above normal. Membrane effluent temperatures increased from 58.8°F to 60.4°F.

All permit-required samples were collected and analyzed. No blending events occurred this month.

**Influent Pumping:** Influent flow was pumped using the small raw sewage pump sets (RSP) every day this month. Two pump sets were required for an average of 10 hours per day. The IPS wet well was “pumped down” on 24 days in February to remove accumulated grease and rags. Influent flow was not directed to South Plant via the Brightwater Diversion Structure and North Creek Pump Station (NCPS) during pump downs this month. As mentioned above, influent flow was directed to South Plant via the Hollywood Pump station on Feb. 14, Feb. 28, and Feb. 29.

**Primary Treatment:** Three of five primary clarifiers (PC), PC-1, PC-2, and PC-3, were in service in January, PC-4 was inspected this month. PC-5 remains out of service because of an apparent leak near the

top of the tank wall. This leak results in puddles of water collecting in an equipment room adjacent to PC-5. Solids return flows were directed to PC-1. Regular cleaning of the primary effluent screens continued.

**Secondary Treatment:** Three aeration basins (AB’s) were in service this month. Aeration basins continued to operate in the “zone-DO” control mode this month. Aeration air flow for the month averaged 10,550-scfm total to the three basins. Filamentous growth was present this month but was not abundant. The MLSS and SRT averaged 8,835-mg/L and 20 days, respectively. Secondary foam was present and did not cause any operational problems. The MLSS was maintained primarily by surface wasting.

Full nitrification was achieved most of this month and denitrification was incomplete. Effluent nitrite/nitrate (NO<sub>2</sub>+NO<sub>3</sub>) and ammonia averaged 32.7-mg/L and 0.2-mg/L as N, respectively. Influent concentrations for total Kjeldahl nitrogen (TKN) and TIN in February were higher than in January, but still in a range that is typical for late winter or early spring weather when the sewage is dilute. Results for December, January, and February are summarized in Table 1. February’s total nitrogen removal was higher than January and December’s. This was not unexpected as total nitrogen removal typically increases as flows decrease and, as noted last month, December’s data was skewed by high flows on Dec. 5 which resulted in a lower than average influent concentrations of TKN and TIN for December.

Denitrification was limited by the inability to maintain lower DO concentrations with the current aeration system. In contrast with the afternoon and evening hours, during the morning hours, the air demand was lower than the minimum air flow for the current blower configuration. Plans for tuning the system include installation of a blow-off valve, which will improve DO control by allowing a lower minimum air flow to the basins. No DO setpoint changes were made this month due to the current limitations in maintaining low DO throughout the day. Any changes to DO setpoints are done slowly to support process stability.

Table 1. Influent and Effluent TKN and TIN concentrations and loading.

	Days in Month	Influent				Effluent				Total N Removal <sup>1</sup>
		Influent TKN, mg/L	Influent TIN, mg/L	Influent Flow, (MGD)	Influent TKN, lbs per day	Effluent TKN, mg/L	Effluent TIN, mg/L	Effluent Flow, (MGD)	Effluent TIN, lbs per day	
Dec	31	38.5	28.8	23.0	7,381	1.8	31.6	23.0	6,159	13%
Jan	31	41.8	30.4	23.9	8,343	1.6	30.7	23.9	6,104	23%
Feb	29	47.4	31.7	21.5	8,491	1.8	32.7	21.4	5,950	27%

<sup>1</sup> Total Nitrogen Removal (TN) is equal to [Influent TKN-(Effluent TKN + Effluent NO<sub>2</sub>+NO<sub>3</sub>)]/Influent TKN and assumes that the Influent NO<sub>2</sub>+NO<sub>3</sub> is very low. TKN is Organic Nitrogen + Ammonia.

Alkalinity in the form of a 59% Mg(OH)<sub>2</sub> solution was added to the secondary process to ensure minimum effluent pH limits were met and to achieve complete nitrification. The 59% Mg(OH)<sub>2</sub> solution dose averaged approximately 2627-gpd or 122-gallons/MG of influent. An additional 703 gallons of 25% NaOH was also used for alkalinity addition in this month. The NaOH addition occurred by gravity flow with the suction and discharge of the NaOH pumps left open and the dosing pumps off. Leaving the pumps valved in facilitated availability of the NaOH pumping in the event that the demand quickly increases due to low influent alkalinity, higher ammonia loading from the solids area, or low Mg(OH)<sub>2</sub> inventory.

Membrane effluent turbidity averaged 0.02 - 0.03 NTU. Membrane Trains were in “relax” mode and LEAP “low” mode this month because filterability was very good. Approximately 2400-gallons of 12.5% sodium hypochlorite [NaOCl] were used for membrane maintenance cleans. An additional 2,240 gallons of NaOCl were used for recovery cleans on Trains 1, 2, and 6.

Membrane capacity ranged between 41-MGD and 46-MGD this month. This range was above the range needed to process the average influent flow. Plans are in place to rebuild the effluent check valves for all trains in the coming year to prevent the effluent pumps from shutting down. Soluble COD (sCOD) in the mixed liquor averaged 48-mg/L; this parameter has been well correlated with permeability (lower sCOD is correlated with higher permeability). The maximum hourly flux during peak flow tests was between 16.8-gpd and 17.3-gpd per ft<sup>2</sup> of membrane surface.

Table 2 shows the weekly average trans-membrane pressure (TMP), membrane permeability, and SRT. Flow setpoints for the peak flow tests are normally adjusted up/down depending on the TMP before backpulse and anticipated influent flow. The rated instantaneous peak hourly flow for one membrane train is 4,950-gpm. The peak flow setpoint was 4,700-gpm throughout this month. Results from peak flow tests facilitate discerning when a blending event could occur (requiring chemically enhanced primary treatment). All peak flow tests were run with trains in backpulse mode.

Table 2. Trans-membrane pressure, membrane permeability, and SRT.

Parameter	Week ending 2/05	Week ending 2/12	Week ending 2/19	Week ending 2/26
TMP before backpulse, average psi <sup>2</sup>	-1.4	-1.3	-1.3	-1.2
TMP before backpulse, peak flow test, psi	-2.1	-2.0	-2.1	-2.0
Permeability temperature-corrected <sup>1</sup> , gfd/psi	9.2	9.6	9.4	9.3
Flow target for peak flow test, gpm <sup>3</sup>	4700	4700	4700	4700
Flow hourly average during peak flow test, gpm	3855	3840	3885	3835
MBR Effluent temperature, degrees F	58.9	60.0	59.9	60.3
SRT, days	23	20	17	20
MLSS, mg/L	9260	8580	9085	8745
ML soluble COD, mg/L	35	62	nm <sup>4</sup>	nm <sup>4</sup>

1 Temperature-corrected Permeability based on Peak Flow Test.

2 TMPs during the moderate flow period of the day

3 Flow target is the instantaneous flow, the hourly flow takes into account time the train is not in production.

4 ML soluble COD was not measured between Feb14 and Feb 27 to accommodate laboratory schedules

**Disinfection:** Approximately 6,378 gallons of 12.5% NaOCl was used in February for final effluent disinfection. The NaOCl effluent disinfection dose averaged 1.5-mg/L as Cl<sub>2</sub>. The monthly average and maximum weekly effluent Cl<sub>2</sub> residual at the outfall (aka Point Wells) were both 0.06-mg/L; both met both the monthly and max-weekly permit limits.

**Odor Control:** All odor control areas had the design-specified number of trains in service; four for Headworks, and three each for Secondary and Solids, except for 15 hours on Feb. 26 when pressure sensor alarms caused the Headworks area OC fan 1 to trip offline. Air balancing work will continue next month when upstream ducts in all process areas can be cleaned and repaired.

**Thickening:** All three gravity belt thickeners (GBTs) operated in February. The GBTs thickened approximately 12.1 MG of feed sludge from an average of 1.5% total solids (TS) to 5.7% TS, with an average solids capture of 94.3%. Sludge loading to the thickeners totaled 771 dry tons. The polymer dose for thickening averaged 3.9 pounds active polymer per dry tons solids processed. The thickening and swing polymer blending units operated normally during the month.

**Anaerobic Digestion:** The digestion process met time and temperature requirements for Class B biosolids for the month. The temperature in the active digesters averaged 99.0°F and the solids retention time (SRT) averaged 32.9 days, and volatile solids (VS) destruction averaged 59.8%. The total solids concentration in the active digesters averaged 2.6% with a VS fraction of 80.6% VS/TS. Draft tube mixers in Digester 2 (mixer 2) and Digester 3 (mixer 2) were removed in September for repair. A hairline crack was discovered on the Digester 1 Mixer 1 flange, where it was previously welded in 2018. The mixer will remain in place and out of service to reduce potential vibrations that would place additional stress on the crack. Safety staff have determined the likelihood of crack propagation is minimal and that the hazardous emissions emanating from the fissure are minimal. The area has been roped off to limit traffic and staff are periodically checking the crack for expansion. Plans to take the digester out of service to repair the crack are scheduled for 2024.

**Dewatering/Biosolids:** All biosolids met the requirements for Class B. Dewatering operated 25 days in February, using both centrifuges. Centrifuge feed averaged 2.3% TS and 81.4% VS/TS for the month. Centrifuge biosolids product for Centrifuge 1 averaged 21.5% TS at 83.6% VS/TS and product for Centrifuge 3 averaged 21.2% TS at 83.8% VS/TS. A total of 289 dry tons of solids were processed (according to the feed flow meters and % solids) and 1,293 wet tons (276.2 dry tons at 21.4% TS) of biosolids cake were produced. A total of 1,347 wet tons (288 dry tons) of biosolids cake were hauled in February. Solids recovery in the dewatering process averaged 95.2%. Polymer dosage averaged 51.2 lbs-active per dry ton produced. The dewatering polymer unit operated normally during the month. Plans to replace all three skid units (thickening, dewatering, and the swing unit) are ongoing.