

MEMORANDUM

March 12, 2024

TO: Historical Memo

FM: Matt Macdonald

RE: Vashon Wastewater Treatment Plant – February 2024

The Vashon Wastewater Treatment Plant effluent met all water quality requirements in February 2024. Effluent Biochemical Oxygen Demand (BOD₅) averaged 2.1-mg/l and Total Suspended Solids (TSS) averaged 3.3-mg/l. BOD₅ and TSS removals were 99% and 98%, respectively. All required analytical testing was completed in February.

February 2024 had a below-average amount of rainfall with 4.84-inches of rainfall recorded at the nearby Judd Creek station and 3.84-inches of rainfall recorded at SeaTac Airport; the 30-year historical average for SeaTac Airport in February is 5.09-inches. Influent flow averaged 0.278 million gallons per day (MGD) in February 2024. The maximum daily flow of 0.503-MGD occurred on February 28 in response to 1.49-inches of rain that day. Peak hourly flow on February 27 was 0.666-MGD during which the average turbidity was <5-NTU. Effluent temperature in February averaged 11.9°C.

The oxidation ditch was operated at an average solids retention time¹ of 21-days. The dissolved oxygen (DO) control set-point was 0.8-mg/L. Mixed liquor TSS averaged 5,000-mg/L, and ranged from 4,200-mg/L to 5,300-mg/L. The sludge volume index, which measures the mixed liquor's settling characteristics, averaged 168-mL/g. An estimated 4,700 dry pounds of waste activated sludge was hauled to South Plant for further treatment in February.

Both Clarifiers were in service for the duration of February and will remain in service for the wet season. The UV system operated with both units in auto.

A set of samples was collected on February 6 and February 14 for nutrient analysis. Monthly total nitrogen (TN) removal was 93%, with an average effluent TIN concentration of 1.3-mg/L (0.10-mg/L NH₃-N and 1.2-mg/L NO₂+NO₃ as N). The average daily effluent TIN load was 2.9-lbs/day as N, which results in 84-lbs of TIN as N discharged in February. The cumulative annual TIN loading is 214-lbs². Effluent total phosphorus (Total-P) was 1.0-mg/L. No soda ash was added to the ditch for pH adjustment.

Table 1. Summary of Monthly Flow & Rain

¹ This is not a true solids retention time but rather a metric that is proportional to the solids retention time (the inverse of the Food to Microorganism ratio). It is used for historical consistency.

² As a "Permittee with a small TIN load", the Vashon Wastewater Treatment Plant does not have a numeric "action level" for annual cumulative TIN load under the Puget Sound Nutrient General Permit.

Monthly Total Flow Volume, MG	Monthly Average Flow, MGD	Minimum Daily Flow, MGD	Maximum Daily Flow, MGD	Total Rainfall, Inches
8.074	0.278	0.227	0.503	4.84

Table 2. Summary of Monthly Compliance/Exceptions

Biochemical Oxygen Demand 5-day			Total Suspended Solids			Fecal Coliform (CFU/100 mL)	
Permit mg/L	Actual mg/L	Rem %	Permit mg/L	Actual mg/L	Rem %	Permit	Actual
30	2.1	99	30	3.3	98	200	E1.1

Table 3. Summary of Weekly Compliance/Exceptions

	Biochemical Oxygen Demand (mg/L)		Total Suspended Solids (mg/L)		Fecal Coliforms (CFU/100 mL)	
	Permit	Actual	Permit	Actual	Permit	Actual
Week 1	45	1.9	45	4.4	400	<1
Week 2	45	1.6	45	<2.3	400	E1.5
Week 3	45	2.4	45	4.4	400	E1.0
Week 4	45	2.1	45	4.6	400	<1

Table 4. Summary of Effluent Nitrogen

Average NH ₃ mg/L as N	Average NO ₂ +NO ₃ mg/L as N	Average TIN ³ mg/L as N	Average TKN mg/L as N	Monthly TIN lbs as N	Annual TIN lbs as N	Average Monthly Total N removal %
0.10	1.2	1.3 ⁴	1.0	84	214	93%

³ TIN = Total Inorganic Nitrogen = NH₃ + NO₂+NO₃ (as N)

⁴ Due to rounding errors, the monthly average NH₃-N and NO₂+NO₃ as N don't always add up to the monthly average TIN.